Enclosed Victory Relays: 20A SPST, with HOA Switch

Victory 121, 122, & 123 Series



V121/221





HOA Switch Provides Local Control

FEATURES

- Sleek field enclosure reduces the need for panel space
- The nipple mount feature allows the V121 Series to be mounted to any electrical enclosure easing installation
- Flexible tinned stranded wire...fits easily in tight spaces and provides secure connections to wire nuts
- UL508 Listed...designed and approved for field installation... makes electrical inspection a snap
- Products include a cover that conceals and protects the HOA switch, reducing the likelihood of tampering
- Limit costly control system override & service calls
- The switch position monitors available with the V122/V222 & V123/V223 models allow the control system to notify building operating personnel when a load is inadvertently left ON or OFF

DESCRIPTION

The **Victory 121, 122, and 123 Series** HOA relays have a concealed HOA switch for local control and troubleshooting with limited unauthorized switch manipulation. To further guard against control system override, the V122/V222 and V123/V223 are equipped with a monitored HOA. The V122/V222 provides a two-wire resistive output and the V123/V223 offers a three-wire digital monitor. Now you can enjoy the convenience of local control with none of the drawbacks.

SPECIFICATIONS



| Operating Temp Range | -40° to 60°C (-40° to 131°F) | | | |
|--------------------------------------|--|--|--|--|
| Operating Humidity Range | 10-90% RH non-condensing | | | |
| Expected Relay Life | Electrical (@ rated current) 100,000 cycles; Mechanical (unpowered) 10,000,000 cycles | | | |
| Relay Status | LED ON=energized | | | |
| Insulation Class | 277VAC RMS | | | |
| Agency Approvals | UL 508 | | | |
| WIRE SPECIFICATIONS | | | | |
| Lead Length 14" (356 mm) min. | | | | |
| Gauge | UL1015; Coil: 18 AWG; Contacts: 12 AWG; HOA monitor wires: 16 AWG | | | |
| V122/V222 RESISTIVE MONITOR MAXIMUMS | | | | |
| Voltage Max. | 13.4VAC/DC | | | |
| Current Max. 4mA AC/DC | | | | |
| V123/V223 DIGITAL MONITOR MAXIMUMS | | | | |
| Dry Circuit Contact Rating (Max.) | 24VAC/DC@100mA | | | |

TYPICAL COIL PERFORMANCE

| Voltage | Coil Current | | |
|---------|--------------|------|--|
| | AC | DC | |
| 24V | 75mA | 32mA | |
| 120V | 42mA | - | |
| 208V | 36mA | - | |
| 277V | 49mA | - | |

| CONTACT RATINGS | | | | |
|------------------------|--|--|--|--|
| V121, V221 | | | | |
| Resistive 20A@240VAC | | | | |
| 8A@28VDC | | | | |
| 14A@14VDC | | | | |
| Motor 1HP@120VAC | | | | |
| V122, V123, V222, V223 | | | | |
| Resistive 20A@240VAC | | | | |
| 8A@28VDC | | | | |
| 14A@14VDC | | | | |
| Motor 1HP@250VAC | | | | |


APPLICATIONS

- Command contactors
- Control motors
- Isolation
- Device interlocking
- Relay logic
- Sense voltages for alarm conditions





WIRING DIAGRAM

Nipple mount directly to a panel




Nipple mount to any 2x or 4x electrical box






WIRE COLOR CODES



V123/V223 Digital HOA Position Monitor



HAND = Brown wire closed to Common $\mathsf{OFF} = \mathsf{Both}$ wires open to Common VIOLET = Common

AUTO = Grey wire closed to Common

V122/V222 Resistive HOA Position Monitor

| Switch Positions: HAND ~ 1.4k Ω OFF ~ 6.2k Ω AUTO ~ 3.4k Ω | Cable Faults: OPEN = Infinite Ω SHORT ~ 0Ω | GREY |
|--|---|------|
| 7,010 5.11.12 | | GREY |

| ORDERI | NG I | NFOR | ΜΑΤΙΟ | DN |
|--------|------|------|-------|-----------|

| MODEL | RELAY | COIL | AMPERAGE RATING | HOA | HOA MONITOR | RELAY POWER LED | UL | |
|-------|-------|----------------------|----------------------|-----|-------------|-----------------|----|--|
| V121 | | 24VAC/DC, 120VAC | | | None | • | | |
| V122 | | 24VAC/DC, 120VAC | | | Resistive | • | | |
| V123 | | 24VAC/DC, 120VAC | | 201 | | Digital | • | |
| V221 | I L | 24VAC/DC, 208-277VAC | 20A | | None | • | | |
| V222 | | 24VAC/DC, 208-277VAC | | | Resistive | • | | |
| V223 | | | 24VAC/DC, 208-277VAC | | | Digital | | |

ŲΓ US LISTED E150462

Some devices are plenum rated per UL 1995...see White Paper VWP01 at veris.com for details

